CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-0992:118 Page 1 of 1

CATEGORY: Control Unit (Household)

LISTEE: Napco, 333 Bayview Ave., Amityville NY 11701

Contact: *Edmund Gregorian (631) 842-9400 Fax (631) 842-2726

Model GEMINI GEM-P1632, GEM-P1632-Version2, GEM-P1632-Version 3, GEM-P816, DESIGN:

> GEM-P816-Version 2 and GEM-P816-Version 3 combination fire and burglary alarm control units. Refer to listee's data sheet for detailed product description and operational

considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

> and in a manner acceptable to the authority having jurisdiction. The system must have the secondary power supply capable of operating the system for at least 24 hours (battery standby) in the normal condition and followed by not less than 5 minutes of alarm as required

by code.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as household fire and burglary alarm control units for use with separately listed

compatible initiating and indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition.

NOTE: Burglary and other non-fire functions of this control unit were not examined. 1.

> Fire Alarm Verification feature (delay of fire alarm) shall not be used in California. 2.

> > *Rev 06-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 21, 2004 Date Issued: Listing Expires June 30, 2005

Authorized By: DIANE K. AREND, Senior Deputy

Program Manager